

FC501 Addressable Fire Control Panels

The FC501 easy-to-programme control panel has a 4-line, 40 character per line, LCD module display with a backlight, which provides written information regarding the system status, such as temperature, CO level, and smoke level, and is also used for programming the control panel.

The front panel controls enable text and configuration changes.

The FC501 auto-addressing panel has 3 in 1 loops that can support up to 128 addressable devices and 32 zones.

There are two versions available (1.8A or 2.7A power supply), as well as an optional IP board.

Figure 1: FC501 addressable fire control panel with FC500 repeater



Specifications

- The encolsure and front door are plastic.
- H x W x D: 369mm x 335mm x 115mm

Features

Additional Panel Features

- Up to 400mA current dynamically shared across 3 circuits in 1 loop
- · Auto mapping with Intelli-Zone feature
- · Online Help function
- USB interface dual role Host/Device
- Multi users and multi installers (Up to 2 installers, 8 users)
- · Walk test function
- · 4000 Event Log
- · Loop break location
- On board PSTN communicator
- GSM/GPRS as external module
- Up to 4 repeaters and multifunction interfaces for printer / simplified fire brigade panels
- · Event transmission through PSTN and IP
- · Automatic drift compensation

Software Features

- · Fast and simple system configuration, also offline
- · Transferable user database
- · Device graphic displayed
- · Battery and wiring calculation
- · Customizable cables database
- Visualization of all the devices assigned to a single zone
- Remote real time visualization of control panel loop and zone status, and so on.
- Easy Remote user interface with control buttons (reset, silence, evacuate)
- Multilevel map based on a tree structure
- Access device data from any pages of the map
- Configuration downloadable to USB memory stick
- Capability to print zone label sheet for front panel customization

Ordering information

Table 1: Product and accessories ordering information

Order number	Product details				
Variants					
557.200.719	FC501-L: Triple Circuit Single Loop Panel Icons - 1,8A PSU				
557.200.718	FC501-H: Triple Circuit Single Loop Panel English - 2,7A PSU				
557.200.720	FC501-HK: Triple Circuit Single Loop Panel - 2,7A PSU, Icons				
Accessories: SKU Descr	Accessories: SKU Description				
508.031.742	FC500MFI: Multifunctional Interface				
508.031.743	FC500IP3: IP Module				
508.032.036	FC500BX: Cabinet for Spare 38Ah Batteries				
508.032.037	USB 5m: USB 5m cable type A				
508.032.042	FC500DISPSpare Display				
557.202.726	FC-MAE: FC500 Panels Monitoring Software				
557.200.727	FC500 FireClass Repeater				

Performance characteristics

Table 2: Performance characteristics

	FC501-L	FC501-H and FC501-HK	FC500			
Dimensions H x W x D mm	369 x 335 x 115	234 x 345 x 55.7				
Weight	3 kg		2.7kg			
Operating Temp	-5°C ÷ 40°C	-5°C ÷ 40°C				
Storage Temp	-40 ÷ 80 °C					
Humidity	Up to 95% Non Condensing					
Supply Voltage	230VaC 50Hz - 15/+10%	19 Vdc - 30 Vdc				
PSU Imax	1,8A 2,7A		130 mA (dc)			
Aux output rated voltage	27,6 Vdc	27,6 Vdc	NA			
Max Battery Size	12 Ah	12Ah - 38Ah external box	NA			
Loop Power	200mA	400mA	NA			
IP Rating	IP30	IP30				
Enclosure colour (cabinet and door)	RAL 7035					

Approvals

Table 3: Approvals

	C C CPR Approv				European Type Approvals			International Listings					
	O051 19 Tyco Fire & Security GmbH, Victor von Bruns- Strasse 21, 8212 Neuhausen am Rheinfall, Switzerland.	EN 54-2	EN 54-4	EN 54-21	MED	LPCB	VDS	AFNOR	FNO	SB SC	FP ANZ	HK FSD	TFTF
FC501-L	DoP-2015-4218	х	x	x									
FC501-H FC501-HK	DoP-2015-4219	х	х	х									
FC500IP in FC501-L FC501-H FC501-HK	DoP-2015-4211			х									

All required Declarations and certificates are publically available on the website www.fireclass.net and are searchable by number or model name. The above fire detection products are components designed for use in Addressable Systems exclusively available to registered partners only. They are intended for installation by trained registered personnel only. Systems should be installed and configured according to local regulations.

Comparision of FC501, FC503, and FC506 features

Table 4: Comparison of FC501, FC503, and FC506 features

Feature	FC501	FC506			
Addressable loops					
No. of Loops	1 Loop	1 Loop	2 Loops		
Loop Splitter / Sub- Loops	3	3	6		
Max Current Draw per Loop	0.5A*	1A*	1A*		
No. of Devices	128	250	500		
Outputs		,			
Fault	1	1	1		
Fire	1	1	1		
Programmable Open collector Outputs	2	2	2		
USB Interface	1	1	1		
RS232 Interface	1	1	1		
RS485 Interface	1	1	1		
24V (for RS485 Devices)	1,	1,	1,		
	Max Current: 0.5 A	Max Current: 1 A	Max Current: 1 A		
24 V Auxiliary	1,	1,	1,		
	Max Current: 0.5 A Max Current: 1 A		Max Current: 1 A		
24V Resettable	1,	1,	1,		
Z-1 Resettable	Max Current: 0.5 A	Max Current: 1 A	Max Current: 1 A		
Counday / NAC Outputs	2 , Max Current: 0.5 A	2 , Max Current: 0.5 A	2 , Max Current: 0.5 A		
Sounder / NAC Outputs	per NAC	per NAC	per NAC		
Power supply					
AC Mains Voltage	230Vac -15%/+10%, 50-60Hz				
DCI I-	BAW75T24	BAQ140T24	BAQ140T24		
PSUs	(27.6V, 2.7A)	(27.6V, 5.5 A)	(27.6V, 5.5 A)		
Maximum Battery Size (Inside Panel)	2 (12A/h)	2 (17A/h)	2 (17A/h)		
Maximum Battery Capacity	38 Ah	38 Ah	38 Ah		
Battery Optional Box	YES	YES	YES		
Panel Cabinet	Plastic Box	Metal Box, Plastic Door	Metal Box, Plastic Door		
Management software	<u> </u>	1	<u>I</u>		
-		FireClass console			

Table 4: Comparison of FC501, FC503, and FC506 features

Feature	FC501	FC503	FC506			
Communication	RS232, USB,	RS232, USB,	RS232, USB,			
Channels	RS485,IP	RS485,IP	RS485,IP			
SW Zones	32	128	256			
Number of zonal LEDs	8	8	8			
Auto Addressing	YES	YES	YES			
Events logged	4000	4000	4000			
FC500 MFI Interface	4	4	4			
FC500 Repeaters	4	8	8			
FC500 Clients	No Support	7	7			
Standard compliance						
EN54-2	X	Х	Х			
EN54-4	х	Х	Х			
EN54-21	х	Х	Х			
Communicators						
PSTN (Voice, Data)	On Board	On Board	On Board			
IP	FC500IP (Add On)	FC500IP (Add On)	FC500IP (Add On)			

⁽i) **Note:** *Absolute maximum value, the panel displays a warning on the screen when the current exceeds 80% of the maximum value.

